



CABINET	E	F	G
"M"	560	610	915
"P-1"	560	765	1220
"R-1"	560	915	1220



1. THE GROUNDED SIDE OF THE POWER SUPPLY SHALL BE GROUNDED TO THE CONTROL CABINET GROUND TERMINAL.
2. ALL WIRING SHALL BE NEAT AND FIRM.
3. 28 mm MIN. SPACING BETWEEN CONDUITS IN CABINET BASE. CONDUIT MUST BE CAPPED AT BOTH ENDS UNTIL USED.
4. ALL FIELD TERMINALS SHALL BE SUITABLY IDENTIFIED.
5. IF PVC CONDUITS ALLOWED, CABINET MUST BE GROUNDED WITH 3 mm x 16 mm COPPER CLATED STEEL GROUND ROD.
6. ALL CONDUIT SHALL BE PLACED IN SAME TRENCH WHERE POSSIBLE.

ALL DIMENSIONS ARE SHOWN IN MILLIMETERS (mm) UNLESS OTHERWISE NOTED.

STANDARD DRAWING TITLE	(METRIC)		UTAH DEPARTMENT OF TRANSPORTATION		REVISEMENTS	
	CONTROLLER BASE DETAILS		STANDARD DRAWINGS FOR ROAD AND BRIDGE CONSTRUCTION SALT LAKE CITY, UTAH		CONNECTED TAPER IN DIMENSION FOR ENDQUIT SIZE IN THREE PLACES.	
STANDARD DWG. NO.	745-55K		RECOMMENDED FOR APPROVAL		1. 10/12/80	
			DESIGNED BY			
			CHECKED BY			
			DRAWN BY			
			MAY 12 1980			
			STANDARD STANDARDS COMMITTEE			
			APPROVED			
			DATE			
			MAY 12 1980			
			DEPUTY DIRECTOR			
			NO.		APPROVAL	
			REMARKS			